STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 112132
Permit No.
Basin 089

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65559

1. OWNER Bruce Guimont
MAILING ADDRESS 2990 Eagle Washe Valley
ADDRESS AT WELL LOCATION 2990 Eagle
Washoe Valley NV

2. LOCATION NE ¼ SE ¼ Sec 31 T 17N N/S R 20 E
PERMIT/WAIVER No. 050-401-18 (Issued by Water Resources) Parcel No.
Latitude 39 17.508' Longitude 119 46.329"
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name: County: Washoe

3. WORKED PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other...

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	22	22
Brown Sand and Rock		22	31	9
Brown Sand		31	135	104
Fractured Black Rock	X	135	147	12
Brown Sand	X	147	188	41
Brown Clay and Black Gravel	X	188	240	52

39.291889°N NAD27
119.771133°W

* original log unknown

Date started 16-Sep , 20 10
Date completed 21-Sep , 20 10

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
16.5	@ 175	1
18	@190	2

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	20
6 5/8	4	SDR21	20	240

Perforations:
Type of perforation Factory Screen
Size of perforation
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 96 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Blain Drilling & Pump INC (Contractor)
Address PO Box 1255 (Contractor)
Carson City NV 89702
Nevada contractor's license number issued by the *State Contractor's Board* 46498
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2167
Signed (By driller performing actual drilling on site or contractor)
Date Oct 27-10

(Rev. 06/10)
USE ADDITIONAL SHEETS IF NECESSARY

MMH-P