WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 112185
Permit No.
Basin 156

NOTICE OF INTENT NO. 66407 (i)

1. OWNER Craig Renk / Cleary Family Trust
MAILING ADDRESS 2274 Genoa Street
Genoa NV 89411
ADDRESS AT WELL LOCATION NO 3 Moores
Station NYE County NV

2. LOCATION ~~NE~~ SE ¼ NW ¼ Sec. ~~15~~ 36 T. 10 N/S R. 51 E/W NYE County
PERMIT NO. 0 (Issued by Water Resources) 009-581-02 (Parcel No.) 0 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand - Gravel		0	80	80
Hard Rock		80	130	50
Fractured Rock		130	145	15
Hard Rock		145	155	10
Gps W 65 84				
N 38° 41. 178				
W 116° 11. 186				
38.686366°N NAD27				
116.185706°W				

Date started 11-3-2010, 20
Date completed 11-4-2010, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
2		2

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	155 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	PVC	Sch 40	0	155
8 5/8	16.96	.188	0	8

Perforations:
Type perforation Saw cut
Size perforation 1/8" x 3"
From 105 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 105 feet to 155 feet

9. WATER LEVEL
Static water level 70' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 54 (Contractor)
Hiko NV 89017
Nevada contractor's license number issued by the State Contractor's Board 0028866
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1181
Signed Mike Davis (By driller performing actual drilling on site or contractor)
Date 11-7-2010

mmH-(F)