

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY
Log No. 112247
Permit No. 29832
Basin Ø32

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 66398

1 OWNER TNT CATTLE CO.
MAILING ADDRESS 30540 SABIN RD. PARMA, ID 83660

ADDRESS AT WELL LOCATION SAND PASS RD.

Subdivision Name: _____ County: Humboldt

2 LOCATION SE ¼ NW ¼ Sec 19 T 38N N/S R 37 E
PERMIT/WAIVER No. 29832
Issued by Water Resources Parcel No.

Latitude 41° 09.392 N UTM E NAD 27
Longitude 117° 51.567 W N NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? YES
If yes, what is replacement well NOI? 64935
Is there an existing well log? YES
If yes, what is NDWR well log #? 15503

4 EXISTING WELL CONSTRUCTION
Depth Drilled 600' Feet Depth Cased 360' Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"		.250"	0'	360'

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:

Type of perforation	Size of perforation	From	To
LOUVERED	3/32" X 2"	150' feet	360' feet

Additional Perforations:

Type of perforator used:	From	To	Number of perfs per linear foot
HOLT AIR PERFORATOR	0' feet	150' feet	6 ROWS

5 WATER LEVEL
Static water level 150' feet below land surface
Artesian flow NO G.P.M. 0 P.S.I.
Water temperature _____ ° F Quality _____

8 WELL PLUGGING MATERIALS

6 Additional Notes or Comments

NAD-27 GPS
41.156632°N
117.858482°W
Plugging of Well Log 15503
Replacement Under 112164

From	To	Material Used	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
0' feet	50' feet	NEAT CEMENT	<input checked="" type="checkbox"/>	<input type="checkbox"/>
50' feet	360' feet	BENTONITE GROUT	<input checked="" type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>

Neat Cement Fluid Weight 15 LBS lbs/gal
Bentonite Grout 20% % bentonite
Date Started 9/29/2010
Date Completed 9/30/2010

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Hydro Resources - West Contractor
Address 4975 W. Winnemucca Blvd. Contractor
Winnemucca, Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board 56797
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1713
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 10-4-10