

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 112331
Permit No. 071
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66720 ⁽¹⁾

1. OWNER Tess Harrer ADDRESS AT WELL LOCATION 4690 forest ave.
MAILING ADDRESS 4690 forest ave. Summa Ranchos Winnemucca, Nv 89445
Winnemucca, Nv 89445 Subdivision Name: forrest County: Humboldt

2. LOCATION SW ¼ NE ¼ Sec 7 T 35N N/S R 38E E Latitude 40 55.555n UTM E NAD 27
PERMIT/WAIVER No. NONE Parcel No. 010-474-01 Longitude 117 44.737w N

3. WORKED PERFORMED New Well Replace Recondition Deepen Other
4. PROPOSED USE Municipal/Industrial Irrigation Test Monitor Stock
5. WELL TYPE Cable RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy loam top soil		0	5	5
Med gravel clay & sand		5	10	5
Sand, small gravel & cobbles		10	80	70
Sand, med gravel & cobbles		80	220	140
Sand small gravel & clay		220	280	60
		280		

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
280		280	

HOLE DIAMETER (BIT SIZE)

	From	To	Feet	Feet
10 7/8	0	280		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	STEEL	.188	0	20
6.900	PVC	sdr21=.450 in	20	280

Perforations:
Type of perforation 6 inch pvc mill horizontal slot screen
Size of perforation 1/32
From 240 feet to 280 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Annular Seal: Yes
Neat Cement _____ to _____ Pumped Poured
Cement Grout 0 to 160 Pumped Poured
Concrete Grout _____ to _____ Pumped Poured
≥30% Bentonite Grout _____ to _____ Pumped Poured
Gravel Pack: Yes No 160 to 280 Pumped Poured
Type: _____ 3/8 minus
Bentonite Chips: Nc 0 to 0 Pumped Poured
Type: _____

Date started: 11/9/2010
Date completed: 11/22/2010
280.00

7. Water Level
Static water level: 172 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: COLD °F
Quality: _____

8. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift x
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)		
AIR			4		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name High Desert Drilling LLC
Contractor
Address 4225 E Mary Way
Contractor
Winnemucca Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board 62237
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2140
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 11-22-2010

USE ADDITIONAL SHEETS IF NECESSARY

MMH - (F)