STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 112399
Permit No.
Basin 137B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66382

1. OWNER Round Mountain Gold
MAILING ADDRESS P.O. Box 480
Round Mountain, NV 89045

ADDRESS AT WELL LOCATION Smokey Valley RP-4R
Round Mountain, NV 89045
Subdivision Name: County: Nye

2. LOCATION NE ¼ SW ¼ Sec 15 T 10N N/S R 43 E
PERMIT/WAIVER No. WPCP NEV0091030 MO-1647
Issued by Water Resources ~~Parcel No.~~

Latitude 38.723903°N
Longitude 117.139588°W
UTM E 48868.7 [X] NAD 27
N 4285940.4 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Gravel		0	5	5
Clay w/s Sand		5	18	13
Sand w/s Clay		18	32	14
Sand w/s Gravel		32	38	6
Clay w/s Sand		38	65	27

Date started: 8-Nov, 20 10
Date completed: 8-Nov, 20 10

9. WELL CONSTRUCTION
Depth Drilled 65 Feet Depth Cased 63 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	0	Feet	65	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1.315	.41	.179	0	63

Perforations:
Type of perforation Well Screen
Size of perforation 0.02
From 45 feet to 63 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 0 to 15 [X] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[X] ≥30% Bentonite Grout 15 to 45 [X] Pumped [ ] Poured
Gravel Pack: [X] Yes [ ] No 45 to 65 [ ] Pumped [X] Poured
Type: SRI #8
Bentonite Chips: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality: Unknown

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the *State Contractor's Board* 29064
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2307
Signed (By driller performing actual drilling on site or contractor)
Date 11/17/2010

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY