

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 112462
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35438

1. OWNER VBL ENVIRONMENTAL SERV.
 MAILING ADDRESS PO BOX 665
PAHRUMP, NV 89041

ADDRESS AT WELL LOCATION 592 S LOLA LN

2. LOCATION NE 1/4 SW 1/4 Sec. 16 T 20
 PERMIT NO. 35-355-06
Issued by Water Resources Parcel No.

N S R 53 E NYE County
BOILING GREEN ACRES Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & CALICHIE		0	120	120
CALICHIE	WB	120	122	2
CLAY		122	156	34
CALICHIE	WB	156	161	5
CLAY		161	184	23
CALICHIE	WB	184	189	5
CLAY		189	214	25
CALICHIE	WB	214	220	6

N36°12'39.1"
 W116°01'31.5"

8. WELL CONSTRUCTION

Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>12.25</u>	<u>0</u>	<u>220</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>3.63</u>	<u>.280</u>	<u>0</u>	<u>220</u>

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8x3
 From 160 feet to 220 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal _____
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 220 feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address 1220 E MANSE RD Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed [Signature] By driller performing actual drilling on-site or contractor
 Date 9/9/2010

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR
 RECEIVED
 SEP 27 2010
 LAS VEGAS OFFICE

Date started 9/9/2010, 19____
 Date completed 9/9/2010, 19____