WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 112463
Permit No.
Basin 162

NOTICE OF INTENT NO. 35436

1. OWNER VBL ENVIRONMENTAL SERV.
MAILING ADDRESS PO BOX 1665
PAHRUMP, NV

ADDRESS AT WELL LOCATION 592 S LOLA LN

2. LOCATION NE 1/4 SW 1/4 Sec. 16 T 20 N/S R 53 E NYE County
PERMIT NO. Issued by Water Resources
35-355-06 Parcel No.
BOILING GREEN ACRES Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
N36°12'39.1"				
W116°01'31.3"				
PERF WELL WITH HOLTY AIR PREFORATOR_4 ROWS FROM 100' TO 50' HIT CONCRETE SEAL @ 50'.				
PUMP NEAT CEMENT FROM 100' TO 20' THROUGH 1-1/4" TRIMIE LINE_CONCRETE FROM 20' TO SURFACE.				

DCNR/DWR
RECEIVED
SEP 27 2010
LAS VEGAS OFFICE

Date started 9/13/2010 , 19__
Date completed 9/13/2010 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled EXISTING Feet Depth Cased EXISTING Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
EXISTING	Inches	0	Feet	100	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	16.94	.188	0	100

Perforations:
Type perforation HOLTZ AIR PERFORATOR
Size perforation 1/4x2
From 50 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address 1220 E MANSE RD Contractor
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed By driller performing actual drilling on-site or contractor
Date 9/13/2010

USE ADDITIONAL SHEETS IF NECESSARY