COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 112464
Permit No.
Basin 212

NOTICE OF INTENT NO. 35503

1. OWNER University Board of Regents
MAILING ADDRESS 4505 S. Maryland Pkwy
Las Vegas, NV 89154
ADDRESS AT WELL LOCATION 4505 S. Maryland Pkwy
LAS VEGAS, NV

2. LOCATION SW ¼ SE ¼ Sec 22 T 21 S R 61 E CLARK County

PERMIT NO. MO-2858A (Issued by Water Resources) 162-22-801-001 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TypeII		0	2'	
Silt		2'	4'	
Caliche		4'	5'	
Silty clay		5'	9'	
Caliche		9'	12'	
Silty gravel	x	12'	14'	
Silty clay		14	16'	
Caliche		16'	18'	
Silty clay		18'	23'	
Caliche		23'	25'	
Gravel	x	25'	26'	
Red clay		26'	30'	
Caliche		30'	32'	
Red silty clay		32'	40'	
Red clay		40'	63'	
Gravel	x	63'	65'	
Red clay		65'	74'	
Gravel	x	74'	75'	
Red clay		75'	80'	
WGS84				
N36 06. 206'				
W115 08. 706'				

Date started 9/14, 20 10
Date completed 9/14, 20 10

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR RECEIVED SEP 29 2010 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
30" Inches	0 Feet	80 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14"	37	.250	+1	79

Perforations:
Type perforation Machine
Size perforation 1/4"
From 10 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 2' ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 10 feet to 80 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 WEST TOMPKINS AVE. (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917
Nevada driller's license number issued by the Division of Water Resources to the on-site driller ABDS2161
Signed
By driller performing actual drilling on site or contractor
Date 9/24/10

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com