

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 112496
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **35440**

1. OWNER **DONAL & PHYLLIS HOOD**
 MAILING ADDRESS **3340 S PAHRUMP VALLEY BLVD**
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION **3340 S PAHRUMP VALLEY BLVD**

2. LOCATION SE 1/4 NE 1/4 Sec. 34 T 20
 PERMIT NO. 40-672-36
Issued by Water Resources Parcel No.

(NS)R 53 E NYE County
UNIT 4A CALVADA VALLEY
Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	4	4
CALICHIE		4	17	13
CLAY		17	56	39
CALICHIE		56	80	24
CLAY		80	115	35
CALICHIE	WB	115	134	19
CLAY		134	145	11
CALICHIE	WB	145	160	15
CLAY		160	171	11
CALICHIE	WB	171	185	14
CLAY		185	200	15

N36°10'13.9"
 W115°59'47.4"

DCNR/DWR
 RECEIVED

OCT 12 2010

LAS VEGAS OFFICE

Date started 10/4/2010, 19
 Date completed 10/4/2010, 19

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>12"</u>	<u>0</u>	<u>200</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>3.63</u>	<u>.280</u>	<u>0</u>	<u>200</u>

Perforations:

Type perforation **SCREEN**
 Size perforation .035
 From 120 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL

Static water level 76 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.


Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.**
Contractor

Address **1220 E MANSE RD**
Contractor

PAHRUMP, NV. 89048

Nevada contractor's license number issued by the State Contractor's Board **47333**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1426**

Signed 
 By driller performing actual drilling on-site or contractor

Date **10/4/2010**