

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 112502
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER DCH Exchange LLC, Harrahs Prop. ADDRESS AT WELL LOCATION 3969 Audrie st. LV, NV
 MAILING ADDRESS 1 Caesars Palace Dr. Las Vegas, NV 89109 Subdivision Name: _____ County: Clerk
 NOTICE OF INTENT NO. 35576
 2. LOCATION SE 1/4 SW 1/4 Sec 16 T 21 N R 61 E Latitude 36° 07.054' UTM E NAD 27
 PERMIT/WAIVER No. MO-2860 16216410054 Longitude 115° 10.073' N NAD 83/WGS 84
 Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test Stock
 Municipal/Industrial Monitor
 5. WELL TYPE
 Cable Rotary RVC
 Other

6. LITHOLOGIC LOG B-2

Material	Water Strata	From	To	Thick-ness
<u>Fill</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Caliche Hard</u>		<u>5</u>	<u>5.5</u>	<u>.5</u>
<u>Gravel w/sand</u>		<u>5.5</u>	<u>13.5</u>	<u>8</u>
<u>Caliche</u>	<u>15.6</u>	<u>13.5</u>	<u>19.5</u>	<u>6</u>
<u>Gravel Hard</u>		<u>19.5</u>	<u>22.5</u>	<u>3</u>
<u>Caliche</u>		<u>22.5</u>	<u>24</u>	<u>1.5</u>
<u>Sand w/gravel</u>		<u>24</u>	<u>34.5</u>	<u>10.5</u>
<u>Gravel</u>		<u>34.5</u>	<u>36</u>	<u>1.5</u>
<u>clayey w/sand</u>		<u>36</u>	<u>45</u>	<u>9</u>
<u>caliche Hard</u>		<u>45</u>	<u>49</u>	<u>4</u>
<u>Clay w/sand</u>		<u>49</u>	<u>95</u>	<u>46</u>
<u>Gravel</u>		<u>95</u>	<u>96.5</u>	<u>1.5</u>
<u>Caliche Hard</u>		<u>96.5</u>	<u>100</u>	<u>3.5</u>

9. WELL CONSTRUCTION
 Depth Drilled 100 Feet Depth Cased 100 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 Inches 0 Feet 100 Feet
 To _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>sch. 40</u>	<u>6</u>	<u>100</u>

 Perforations:
 Type of perforation Factory slot
 Size of perforation 020
 From 90 feet to 100 feet
 From _____ feet to _____ feet
 Annular Seal: Yes No
 Neat Cement 6 to 80 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout 0 to 6 Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured
 Gravel Pack: Yes No 85 to 100 Pumped Poured
 Type: #12 sand
 Bentonite Chips: Yes No 80 to 85 Pumped Poured
 Type: Half plug Pellets

7. Water Level
 Static water level: 15.6 feet below land surface
 Artesian Flow: _____ G.P.M. _____ P.S.I.
 Water Temperature: _____ °F
 Quality: _____

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

DUNN/DWR RECEIVED
OCT 25 2010

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Elite Drilling Inc. Contractor
 Address 4255 W. Post rd. Las Vegas, NV 89118 Contractor
 Nevada contractor's license number 0054931
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 11-1289
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 10/18/10