STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 112526
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34395

1. OWNER FC INCOME PROPERTIES LLC,
MAILING ADDRESS + FLAMINGO CORRIDOR LLC. LEASE 2200 PASEO VERDE PKWY #350 HENDERSON NV 89052

ADDRESS AT WELL LOCATION 280 E FLAMINGO LAS VEGAS NV,
Subdivision Name: County: CLARK

2. LOCATION NW ¼ NE ¼ Sec 21 T 21 N/S R 61 E
PERMIT/WAIVER No. 1622150 1005
Issued by Water Resources Parcel No.

Latitude 36° 06 53 49
Longitude 115° 09 39 24
UTM E N
☐ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other H.S.A.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0.0	.2	.2
STONE, CLAY FILL		.2	4.0	3.8
CALICHE		4.0	8.0	4.0
BROWN SILTY CLAY		8.0	12.0	4.0
CALICHE	YES	12.0	16.0	4.0
BROWN SILTY CLAY	YES	16.0	20.0	4.0
CALICHE	YES	20.0	23.5	3.5
BROWN SILTY CLAY	YES	23.5	25	1.5

FACILITY I.D. NO. H-001356

Date started: 10 - 13 , 20 10
Date completed: 10 - 13 , 20 10

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

	Inches	From Feet	To Feet
8	Inches	0	25
	Inches		
	Inches		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 40	0	26

Perforations:
Type of perforation MACHINE SLOT
Size of perforation
From feet to 2 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☒ Concrete Grout	0'	to 1'	☐ Pumped	☒ Poured
☐ ≥30% Bentonite Grout		to	☐ Pumped	☐ Poured

Gravel Pack: ☐ Yes ☐ No 3' to 25' ☐ Pumped ☒ Poured
Type: No 3
Bentonite Chips: ☒ Yes ☐ No 1' to 3 ☐ Pumped ☒ Poured
Type: 3/8 SEAL

7. Water Level
Static water level: 12.5' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR RECEIVED OCT 25 2010 LAS VEGAS OFFICE

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING (Contractor)
Address 7150 PLACID ST LAS VEGAS NV. 89119 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 10-12-2010

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-06)
(NSPO 3-08)
(O) 627