WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 112551
Permit No.
Basin 162

NOTICE OF INTENT NO. 35437A

1. OWNER GREGORY DANN
MAILING ADDRESS 2221 WINDSONG LN
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION 2350 W DYER CT

2. LOCATION NW 1/4 NE 1/4 Sec. 18 T 20 N/S R 53 E NYE County
PERMIT NO. Issued by Water Resources
36-172-17 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other PLUGGIN

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
N36°12'58.5"				
W116°03'24.4"				
PERF WELL FROM 50' TO 140' WITH MILLS KNIFE_PUMP				
NEAT CEMENT THROUGH 1-1/4"TRIMIE LINE FROM 140'				
TO 10' CONCRETE_FROM 10' TO SURFACE.				

DCNR/DWR
RECEIVED
SEP 10 2010
LAS VEGAS OFFICE

Date started 9/10/2010 , 19__
Date completed 9/10/2010 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
EXISTING	Inches	0 Feet	140 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	16.94	.188	0	140

Perforations:
Type perforation MILLS KNIFE
Size perforation 1/4x3
From 50 feet to 140 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
Contractor
Address 1220 E MANSE RD
Contractor
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed
By driller performing actual drilling on-site or contractor
Date 9/10/2010

USE ADDITIONAL SHEETS IF NECESSARY