WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 112552
Permit No.
Basin

NOTICE OF INTENT NO. 35434

1. OWNER RAYMOND & ELIZABETH RAFFETY
MAILING ADDRESS 4501 E ASHLEY AVE
PAHRUMP, NV 89061

ADDRESS AT WELL LOCATION 4501 E ASHLEY AVE

2. LOCATION NW 1/4 NE 1/4 Sec. 29 T 21 N/S R 54 E NYE County
PERMIT NO. Issued by Water Resources
45-332-16 Parcel No.
GREEN SADDLE RANCH Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
EXISTING		0	160	160
FRACTURED CEMENTED	WB	160		
ROCK			175	15
CLAY & GRAVEL		175	200	25
N36°06'00.6"				
W115°55'52.4"				
SEAL WELL FROM 125' TO SURFACE BETWEEN 4.5 PVC &				
OLD 8" STEEL WELL				

Date started 8/28/2010 , 19__
Date completed 8/28/2010 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
EXISTING	Inches	0	Feet	160	Feet
7-7/8	Inches	160	Feet	200	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5"	2.37	.248	0	200
8"	16.94	.188	0	160

Perforations:
Type perforation SCREEN
Size perforation .020
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal EXISTING
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 200 feet to 125 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address 1220 E MANSE RD Contractor
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed By driller performing actual drilling on-site or contractor
Date 8/28/2010

USE ADDITIONAL SHEETS IF NECESSARY