

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 112619
Permit No.
Basin 092B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66171

1 OWNER CAROL TERRY
MAILING ADDRESS 11630 FIR DR
NW RENO, NV 89506

ADDRESS AT WELL LOCATION 11630 FIR ST
RENO, NV 89506
County: Washoe

2 LOCATION SW 1/4 SE 1/4 15 T 21N N/S R 19 E
PERMIT/WAIVER No. WL 100074 080-931-07
Issued by Water Resources Parcel No.

Latitude 39.68644°N UTM E NAD 27
Longitude 119.83386°W N NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? NO
Is there an existing well log? YES
If yes, what is replacement well NOI?
If yes, what is NDWR well log #? 76976

4 EXISTING WELL CONSTRUCTION
Depth Drilled 293 Feet Depth Cased 293 Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	200
5	11.56	.188	177	293

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why:

Existing Perforations:

Type of perforation	Size of perforation	From	To
FACTORY MILLS SLOT	3 X 3/32	197 feet	233 feet
		253 feet	293 feet

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:

Type of perforator used: MILLS KNIFE

From	To	Number of perfs per linear foot
120 feet	160 feet	4

5 WATER LEVEL
Static water level 256 feet below land surface
Artesian flow _____ G.P.M. P.S.I.
Water temperature POOR °F Quality POOR

8 WELL PLUGGING MATERIALS
Material Used
From 195 feet to 293 feet BENTONITE Pumped Poured
From 0 feet to 195 feet CEMENT GROUT Pumped Poured
From _____ feet to _____ feet Pumped Poured
From _____ feet to _____ feet Pumped Poured
From _____ feet to _____ feet Pumped Poured

6 Additional Notes or Comments
0 TO 195' CEMENT GROUT
195' TO 295' BENTONITE CHIPS
39.686, 531°N NAD27 O.D.
119.833834°W

Neat Cement Fluid Weight 94/4 lbs/gal
Bentonite Grout 1/4 BENT ROUNDS % bentonite
Date Started 12/09/2010
Date Completed 12/09/2010

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. Contractor
Address # 20 KIT KAT DRIVE Contractor
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed *Michael Wash*
Date 12/13/2010
By driller performing actual drilling on site or contractor