WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 112 643
Permit No. 44823
Basin Ø75

NOTICE OF INTENT NO. 32969

1. OWNER Ceresola Brothers
MAILING ADDRESS
ADDRESS AT WELL LOCATION 8 Miles East of Fernley off I 80

2. LOCATION SW ¼ SE ¼ Sec. 25 T. 22 N/S R. 25 E Churchill County
PERMIT NO. 44823 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Because Well only had 4' 8" of Casing Drove And Cemented in it Could Not be pulled.				
The well had Caved in at 400' Ft And the pump was Stuck in the well, they had Tryed to pull it when the 2½" pipe Broke off with the Steel sucker Rod.				
The had Reintered the hole and Got Ahold of the pipe when the Fishing Tool Broke off to.				
We Pumped Abonite Groute to Fill Hole up to 20' Feet Then we Grouted the last 20' Feet.				

Date started 12/18/10, 20
Date complated 12/18/10, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEERS OFFICE
2011 JAN 18 AM 11:33
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled ? Feet Depth Cased 4' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
? Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	23	Sch 40	+8"	4'

Perforations:
Type perforation (N A) open Hole.
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No 4'
Depth of Seal 0-400'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level ? feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc. (Contractor)
Address PO Box 599 (Contractor)
Silver Springs, NV 89429
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed Nathaniel L. Leach (By driller performing actual drilling on site or contractor)
Date Jan 12/11

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY

39.740722°N NAD 27
119.121863°W (TN)