STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 112652
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34390

1. OWNER ACE CAB INC.
MAILING ADDRESS 5010 S VALLEY VIEW BLVD. LAS VEGAS NV.
ADDRESS AT WELL LOCATION 5010 S. VALLEY VIEW BLVD. LAS VEGAS NV.
Subdivision Name:
County: CLARK

2. LOCATION NW¼ NW ¼ Sec 29 T 21 N/S R 61 E
PERMIT/WAIVER No. 162-29-101-043
Issued by Water Resources Parcel No.
Latitude 36° 05' 55" 42
Longitude 115° 11' 26" 08
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		.0	.25	.25
STONE + SAND BASE		.25	1.0	.75
SILTY BROWN CLAY + STONE		1.0	4.0	3.0
CALCHE		3.0	9.0	6.0
SILTY BROWN SAND + SILT		9.0	11.0	2.0
CALCHE		11.0	19	8.0
SILTY BROWN SAND + SILT		19	22	3.0
CALCHE		22	25	3.0

WELL No. VE 2

Date started: 8-17, 20 10
Date completed: 8-17, 20 10

7. Water Level
Static water level: NONE feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR RECEIVED
SEP 10 2010
LAS VEGAS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	25	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		SCH 40	0	25

Perforations:
Type of perforation MACHINE SLOT
Size of perforation .020
From 15 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 1 to 10 ☐ Pumped ☒ Poured
☐ Concrete Grout 0 to 1 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 12 to 25 ☐ Pumped ☒ Poured
Type: NO #3
Bentonite Chips: ☒ Yes ☐ No 10 to 12 ☐ Pumped ☒ Poured
Type: 3/8"

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING (Contractor)
Address 7150 PLACID ST. LAS VEGAS NV. 89119 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
Signed Neil Wilkins (By driller performing actual drilling on-site or contractor)
Date 9-2-2010

(Rev. 05-06) USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627