STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 112819
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34408

1. OWNER Koo TRUST & Koo Erlind altas
MAILING ADDRESS 4330 Nlas Vegas blvd nv 89117

ADDRESS AT WELL LOCATION 4330 Las Vegas blvd

2. LOCATION NE ¼ SW ¼ Sec 4 T 20 N/S R 62 E
PERMIT/WAIVER No. 14004032009
Issued by Water Resources Parcel No.

Latitude 36.14.19.22
Longitude 115.03.25.38
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name: *County:* Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. 302 PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... has

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
asphalt		0	2"	#####
gravel &sand		2"	2'	#####
clay & sand		2'	11'	#####
Calielek		11'	14.5'	#####
sand clay & gravel		14.5'	35'	#####
clay & sand		35'	47'	#####
sand gravel &clay		47'	59	#####

DCNR/DWR
RECEIVED
OCT 14 2010
LAS VEGAS OFFICE

Date started 11-Oct , 20 10
Date completed 11-Oct , 20 10

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

3711001 well 1

8. WELL CONSTRUCTION
Depth Drilled 59 Feet Depth Cased 59 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	59 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	pvc	sch 40	0	59

Perforations:
Type of perforation slolled slrich
Size of perforation 0.02
From 39 feet to 59 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 36
Placement Method: ☐ Pumped ☑ Poured
Gravel Packed: ☑ Yes ☐ No
From 36 feet to 59 feet

Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 47 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services llc (Contractor)
Address 7150 Placid street (Contractor)
Las Vegas NV 89119
Nevada contractor's license number issued by the *State Contractor's Board* 51266
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2097
Signed (By driller performing actual drilling on site or contractor)
Date 10/12/2010

(Rev. 06/10)
USE ADDITIONAL SHEETS IF NECESSARY