

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 112842
Permit No. _____
Basin 179

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66436

1. OWNER ROBINSON NEVADA MINING CO.
MAILING ADDRESS P.O. BOX 392 RUTH, NV 89319
NW SE 14

ADDRESS AT WELL LOCATION ROBINSON MINE

2. LOCATION NW 1/4 SE 1/4 Sec 13 T 16 N SR 62 E
PERMIT/WAIVER No. 78186

Subdivision Name: _____ County: White Pine
Latitude _____ UTM E 938500 NAD 27
Longitude _____ N 27886000 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
<u>TOP SOIL</u>		<u>0</u>	<u>15'</u>	<u>15'</u>
<u>BROWN ROCK</u>		<u>15'</u>	<u>640'</u>	<u>625'</u>
<u>BLACK/GRAY ROCK</u>		<u>640'</u>	<u>1200'</u>	<u>560'</u>
<u>BLANK CASING SCREEN BLANK</u>		<u>42'</u>	<u>580'</u>	
		<u>580'</u>	<u>1190'</u>	
		<u>1190'</u>	<u>1190'</u>	

9. WELL CONSTRUCTION			
Depth Drilled	Feet	Depth Cased	Feet
<u>1,200'</u>		<u>1,190'</u>	
HOLE DIAMETER (BIT SIZE)			
	From	To	
<u>6 3/4</u>	Inches <u>20'</u>	Feet <u>1,200'</u>	Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 3/8</u>		<u>SCHEDULE 40</u>	<u>1,190</u>	<u>+2</u>

Perforations:
Type of perforation SLOT
Size of perforation 0.0125
From 1,180' feet to 580' feet
From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement 30' to 0' Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No 1,200' to 100' Pumped Poured
Type: 3/8 GRAVEL
Bentonite Chips: Yes No 100' to 90' Pumped Poured
Type: TRANSITION SAND

Date started: 12-17-10 20 10
Date completed: 12-20-10 20 10

7. Water Level
Static water level: 635' feet below land surface
Artesian Flow: NO G.P.M. _____ P.S.I. _____
Water Temperature: _____ °F
Quality: GOOD

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>75</u>		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BOB LONGYEAR NEVADA Contractor
Address P.O. BOX 2748 ELKO, NV 89999 Contractor
Nevada contractor's license number _____
issued by the State Contractor's Board 0073086
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2426
Signed John McNamee
By driller performing actual drilling on-site or contractor
Date 12-20-10

STATE OF NEVADA
2011 JAN 20 AM 10:35
RECEIVED

USE ADDITIONAL SHEETS IF NECESSARY
39.249055° N
114.958360° W
NAD 27 (12)