WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 112861
Permit No.
Basin

NOTICE OF INTENT NO. 33225

1. OWNER CLARK COUNTY
MAILING ADDRESS HENDERSON, NV

ADDRESS AT WELL LOCATION RIDGE RIVER ST

2. LOCATION SE 1/4 NE 1/4 Sec. 31 T 21 N/S R 63 E CLARK County
PERMIT NO. Issued by Water Resources
160-31-599-005 Parcel No.
WESTON HILLS Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other PLUG

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| N36°04'54.8" | | | | |
| W114°58'48.9" | | | | |
| PULLED CASING FROM HOLE. | | | | |
| PUMPED NEAT CEMENT FORM BOTTOM UP THROUGH 1" | | | | |
| TRIMIE PIPE. | | | | |
| USED 5.6 CU FT OF NEAT CEMENT WITH 4% BENTONITE. | | | | |

DIVISION RECEIVED DEC 14 2010 LAS VEGAS OFFICE

Date started 10/12/2010 , 19__
Date completed 11/23/2010 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| EXISTING | Inches | Feet | Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2" | .705 | SCHED 40 | 0 | 40 |
| | | | | |
| | | | | |

Perforations:
Type perforation SCREEN
Size perforation .020
From 20 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level NO WATER feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address 1220 E MANSE RD Contractor
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed By driller performing actual drilling on-site or contractor
Date 11/23/2010

USE ADDITIONAL SHEETS IF NECESSARY