WAIVER: R-662

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 112945
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66367 (i)

1. OWNER Florence Holt
MAILING ADDRESS 1160 Harrigan Road
Fallon, NV 89406

ADDRESS AT WELL LOCATION 1160 Harrigan Rd.
Fallon, NV 89406
Subdivision Name: County: Churchill

2. LOCATION NE ¼ SE ¼ Sec 31 T 19N N/S R 29 E
PERMIT/WAIVER No. R-662 007-771-11
Issued by Water Resources Parcel No.

Latitude 39.46423 N
Longitude -118.76354 W
UTM E
N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	5	5
Brown Clay		5	11	6
Brown Sand		11	19	8
Fine Brown Sand	XX	19	26	7

see corresponding plugging log #112944

RECEIVED 2011 FEB -8 AM 10:18 STATE ENGINEER'S OFFICE

Date started: 25-Jan, 20 11
Date completed: 25-Jan, 20 11

7. Water Level
Static water level: 6 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality: Unknown

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
39.46312°N	NAD27 D.D.	
118.76255°W	-GPS-	

9. WELL CONSTRUCTION
Depth Drilled 26 Feet Depth Cased 26 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	26	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.92	.188	0	20
6	4.0	.316	20	26

Perforations:
Type of perforation Saw Cut
Size of perforation 0.125
From 23 feet to 26 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 10 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout 10 to 22 ☒ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 22 to 26 ☐ Pumped ☒ Poured
Type: 3/8" well gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the *State Contractor's Board* 29064
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1753
Signed Wayne Parsons (By driller performing actual drilling on site or contractor)
Date 1/25/2011

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

mmk-(8)