STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113016
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34394

1. OWNER Koo Trust &Koo Erlind altas
MAILING ADDRESS 4330 Nlas Vegas blvd nv 89117
ADDRESS AT WELL LOCATION 4330 Las Vegas blvd

2. LOCATION NE ¼ SW ¼ Sec 4 T 20 N/S R 62 E
PERMIT/WAIVER No. 14004302010 (Issued by Water Resources) Parcel No.
Latitude 36.14.20.38 Longitude 115.03.23.37 Subdivision Name:
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84
County: Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☑ Other... HAS

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
asphalt		0	2"	#####
gravel &sand		2"	2'	#####
clay & sand		2'	14'	#####
Calielek		14'	16.5	#####
sand clay & gravel		16.5	35'	#####
clay & sand		35'	47'	#####
sand gravel &clay		47'	59	#####

Date started 11-Oct , 20 10
Date completed 11-Oct , 20 10

DCNR/DWR RECEIVED OCT 14 2010 LAS VEGAS OFFICE

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

3711001 well 2

8. WELL CONSTRUCTION
Depth Drilled 58 Feet Depth Cased 58 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	58	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	pvc	sch 40	0	58

Perforations:
Type of perforation slolled slrich
Size of perforation 0.02
From 39 feet to 59 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 35
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 36 feet to 58 feet

9. WATER LEVEL
Static water level 46.5 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services llc (Contractor)
Address 7150 Placld street (Contractor)
Las Vegas NV 89119
Nevada contractor's license number issued by the *State Contractor's Board* 51266
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2097
Signed (By driller performing actual drilling on site or contractor)
Date 10/12/2010

(Rev. 06/10)
USE ADDITIONAL SHEETS IF NECESSARY