

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 113030
Permit No. 18987
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66474

1 OWNER CITY OF ELKO ADDRESS AT WELL LOCATION 786 COMMERCIAL STREET
MAILING ADDRESS 571 IDAHO STREET ELKO, NV WELL 19
ELKO, NV 89801 Subdivision Name: ELKO CITY County: ELKO

2 LOCATION SE ¼ NE ¼ Sec 15 T 34N N/S R 55 E Latitude 40.833643 UTM E NAD 27
PERMIT/WAIVER No. R-660 001-352-007 Longitude 115.759062 N NAD 83/WGS 84
Issued by Water Resources Parcel No.

3 TYPE OF WELL Is this well being plugged because a replacement well was drilled? NO Is there an existing well log? YES
 Domestic Irrigation Test Stock If yes, what is replacement well NOI? If yes, what is NDWR well log #? 5262
 Municipal/Industrial Monitor Stock

4 EXISTING WELL CONSTRUCTION

Depth Drilled 400 Feet Depth Cased 400 Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	42	.250	-6	400

7 WELL PLUGGING PROCEDURE

Was well cleaned out to total depth? yes no

If well was not cleaned out to total depth, please explain why: TREMIE PIPE
WENT ALL THE WAY TO THE BOTTOM OF THE WELL

Was the well contaminated? yes no

Was the casing pulled? yes no

Was the casing over drilled? yes no

If casing was left in place, please show where additional perforations were made:

Existing Perforations:

Type of perforation	Size of perforation	From	To
	1/8" X 2 1/2"	108 feet	395 feet

Additional Perforations:

Type of perforator used:	From	To	Number of perfs per linear foot
N/A			

5 WATER LEVEL

Static water level 32 feet below land surface

Artesian flow G.P.M. P.S.I.

Water temperature COLD °F Quality

8 WELL PLUGGING MATERIALS

From	To	Material Used	NEAT CEMENT	Poured
-6 feet	400 feet		<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
			<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
			<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
			<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
			<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
			<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

6 Additional Notes or Comments

19 YARDS OF NEAT CEMENT WAS PUMPED INTO WELL FROM BOTTOM TO GOUND LEVEL IN VAULT

40.833722° N NAD27
115.758161° W D.D.

Neat Cement Fluid Weight 16 lbs/gal

Bentonite Grout % bentonite

Date Started 26-Jan-11

Date Completed 26-Jan-11

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING INC Contractor

Address P. O. BOX 850 Contractor
ELKO, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1166

Signed Dale C. Veden By driller performing actual drilling on site or contractor

Date 28-Jan-11

STATE ENGINEERS OFFICE
2011 FEB 14 AM 11:27

USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED

MAINT