

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 113093  
Permit No. \_\_\_\_\_  
Basin 101

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66372

1. OWNER Teri Whiteley-Soden  
MAILING ADDRESS P.O. Box 977  
Fallon, NV 89407

ADDRESS AT WELL LOCATION 4840 Schindler Rd  
Fallon, NV 89406  
Subdivision Name: \_\_\_\_\_  
County: Churchill

2. LOCATION SE ¼ SW ¼ Sec 9 T 18N N/S R 28 E  
PERMIT/WAIVER No. R-666 006-292-44  
Parcel No. \_\_\_\_\_

Latitude 39.43134 N UTM E \_\_\_\_\_  NAD 27  
Longitude -118.85089 W N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Brown Sand		0	6	6
Brown Clay		6	15	9
Brown Sand		15	22	7
Fine Brown Sand		22	30	8
Gray Clay		30	35	5
Gray Sand		35	44	9
Gray Silt		44	73	29
Gray Sand		73	79	6
Brown Clay		79	83	4
Brown Sand	XX	83	90	7

\* See corresponding NDI # 66373

RECEIVED  
2011 MAR -2 AM 11:03  
STATE ENGINEERS OFFICE

39.431422°N  
118.849903°W

NAD 27 0-0  
-666-

WELL CONSTRUCTION				
Depth Drilled	90	Feet	Depth Cased	90
HOLE DIAMETER (BIT SIZE)				
	From	To		
12.25	Inches 0	Feet 90	Feet	
	Inches	Feet	Feet	
	Inches	Feet	Feet	

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.92	.188	0	10
6	4.0	.316	10	90

Perforations:				
Type of perforation	Saw Cut			
Size of perforation	0.125			
From 87	feet to	90	feet	
From	feet to		feet	
From	feet to		feet	
From	feet to		feet	
From	feet to		feet	

Annular Seal:  Yes  No

Neat Cement 0 to 10  Pumped  Poured  
 Cement Grout to  Pumped  Poured  
 Concrete Grout to  Pumped  Poured  
 ≥30% Bentonite Grout 10 to 50  Pumped  Poured

Gravel Pack:  Yes  No 50 to 90  Pumped  Poured  
 Type: 3/8" well gravel

Bentonite Chips:  Yes  No to  Pumped  Poured  
 Type: \_\_\_\_\_

Date started: 10-Feb 20 11  
Date completed: 10-Feb 20 11

7. Water Level  
Static water level: 13 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: Cool °F  
Quality: Unknown

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
Air	10		1 HR

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Parsons Drilling, Inc.  
Contractor  
Address P.O. Box 1265  
Contractor  
Fallon, NV 89407  
Nevada contractor's license number issued by the State Contractor's Board 29064  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753  
Signed Wayne Ramsey  
Date 2/28/2011