STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 173096
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

*Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 63388

1. OWNER 7-Eleven Inc % AV Tax Dept #29648
MAILING ADDRESS P.O. Box 711
Dallas, TX 75521-0711

ADDRESS AT WELL LOCATION 4601 E. Sunset RD
AS-3 Henderson, NV

2. LOCATION NE ¼ NW ¼ Sec 5 T 22S N/S R 62 E
PERMIT/WAIVER No. 178-05-101-005
Issued by Water Resources Parcel No.

Latitude 36 04'14.12"
Longitude 115 04'25.20"
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name: County: Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fill | | 0 | 3 | 3 |
| Sand (fine to coarse grained) | | 3 | 27 | 24 |
| Volcanic rock | | 27 | 42 | 15 |
| Sandy Clay | | 42 | 50 | 8 |
| AS-3 & SVE-3 are nested wells | | | | |

Date started 10-Dec , 20 10
Date completed 21-Dec , 20 10

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | .5 |

DCNR/DWR RECEIVED
JAN 06 2011
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 Inches | 0 Feet | 50 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.375 | | SCH 40 | 0 | 50 |

Perforations:
Type of perforation Factory Slotted
Size of perforation 0.02
From 47 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 41
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 44 feet to 50 feet

9. WATER LEVEL
Static water level 41 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 739 W. Sunset RD
Contractor
Henderson, NV 89015
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2381
Signed
By driller performing actual drilling on site or contractor
Date

(Rev. 06/10)
USE ADDITIONAL SHEETS IF NECESSARY