STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 13109
Permit No.
Basin 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45934

1. OWNER Pilot Travel Centers LLC
MAILING ADDRESS 5508 Lenas Rd
Knoxville, TN 37909

ADDRESS AT WELL LOCATION Flying J 1880 W. Winnemucca B2
Winnemucca NV
Subdivision Name:
County: Humboldt

2. LOCATION SE ¼ SW ¼ Sec 30 T 36 0 N/S R 38 E
PERMIT/WAIVER No. 5-000254 (Issued by Water Resources) 015-292-08 (Parcel No.)

Latitude N 40.96049°
Longitude W 117.74724°
UTM E
N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Gravel	No	0	10	10
Sand	Yes	10	25	15
Sandy Gravel	Yes	25	30	5

MW-19

40.960587°N NAD27
117.746277°W

Date started: 1/11/11, 20
Date completed: 1/11/11, 20

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10"	Inches	0	Feet	30'	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		Schedule Seal	0	5
4"		Schedule 40		

Perforations:
Type of perforation Factory slot
Size of perforation .010
From 5 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 2.5 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 4.5 to 30 ☐ Pumped ☒ Poured
Type: Silica Sand 10/20
Bentonite Chips: ☒ Yes ☐ No 2.5 to 4.5 ☐ Pumped ☒ Poured
Type: 3/8 Bentonite chips

7. Water Level
Static water level: 11' feet below land surface
Artesian Flow: no G.P.M. P.S.I.
Water Temperature: 65 °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
2011 FEB 17 AM 11:21
STATE ENGINEERS OFFICE

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz-Tech Drilling Inc (Contractor)
Address PO Box 940, Meridian Id 83680 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2412-M-LTD
Signed (By driller performing actual drilling on-site or contractor)
Date 2/9/11

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627