STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113120
Permit No.
Basin 087

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

*Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340*

1. OWNER D&J Holdings, LLC
MAILING ADDRESS 295 Sparks Blvd.
Sparks, NV 89434-8988

NOTICE OF INTENT NO. 66317
ADDRESS AT WELL LOCATION Facility ID - 4-000984 GEW-2
295 Sparks Blvd. Sparks, NV 89434
Subdivision Name: County: Washoe

2. LOCATION NE ¼ NE ¼ Sec 10 T 19N N/S R 20 E
PERMIT/WAIVER No. 21601 (Issued by Water Resources) 037-030-13 (Parcel No.)
Latitude 39°31'59.18" N
Longitude 119°42'58.95" W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Gravel Clay Mix | | 0 | 10 | 10 |
| Brown Silty Sand with Fine Silts | | 10 | 45 | 35 |

Date started: 19-Jan, 20 11
Date completed: 19-Jan, 20 11

7. Water Level
Static water level: 11 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

9. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 12 | Inches | 0 | Feet | 45 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | | Sch 40 | 0 | 45 |
| | | | | |
| | | | | |

Perforations:
Type of perforation Slot
Size of perforation .020
From 5 feet to 45 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 3 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 4 to 45 ☐ Pumped ☒ Poured
Type: #3 Sand
Bentonite Chips: ☒ Yes ☐ No 3 to 4 ☐ Pumped ☒ Poured
Type: Medium Chips

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cascade Drilling, L.P. (Contractor)
Address 3632 Omec Circle (Contractor)
Rancho Cordova, CA 95742
Nevada contractor's license number issued by the *State Contractor's Board* 73966
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-1991
Signed (By driller performing actual drilling on site or contractor)
Date 2/23/2011

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

39.533194°N
119.715355°W
NAD 27 (TA)

RECEIVED 2011 MAR -4 AM 11:09 STATE ENGINEER'S OFFICE