STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113124
Permit No.
Basin Ø64

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

*Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 63101 (i)

1. OWNER Dennis Fowler
MAILING ADDRESS 85 E 6th ST.
Battle Mtn NV 89820

ADDRESS AT WELL LOCATION 2350 Allen Road
Subdivision Name: Lot #5 County: Landon

2. LOCATION NE ¼ NE ¼ Sec 10 T 32 N/S R 44 E
PERMIT/WAIVER No. 010-270-05
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 499979 ☒ NAD 27
N 4501755 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 20 | 20 |
| Yellow Clay | | 20 | 40 | 20 |
| Blue Clay | | 40 | 100 | 60 |
| Tan Clay | | 100 | 160 | 60 |
| Brown Clay With Soft Streaks | | 160 | 240 | 80 |

RECEIVED
2011 FEB 18 AM 10:49
STATE ENGINEERS OFFICE

Date started: 2-2, 2011
Date completed: 2-7, 2011

9. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 5/8 | Inches | 0 | Feet | 240 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | +1 | 240 |

Perforations:
Type of perforation Sawed
Size of perforation
From 140 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥80% Bentonite Grout 5 to 60 ☐ Pumped ☒ Poured
Gravel Pack: ☒ Yes ☐ No 130 to 240 ☐ Pumped ☒ Poured
Type: 3/8
Bentonite Chips: ☒ Yes ☐ No 60 to 130 ☐ Pumped ☒ Poured
Type: 3/8

7. Water Level
Static water level: 90 ft. feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Good.

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Rotary | 80+ | UNK | 4 Hrs |

40.668571°N NAD 27
117.000248°W

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LBJ DRILLING & PUMP COMPANY, INC.
Contractor
Address P.O. BOX 902 - Winnemucca, NV 89446
Contractor

Nevada contractor's license number issued by the State Contractor's Board 0009605A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1807

Signed Joe Boggio
By driller performing actual drilling on site or contractor Joe Boggio
Date

(Rev. 06-08)

USE ADDITIONAL SHEETS IF NECESSARY

MMH (F)