ORIGINAL

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113126
Permit No.
Basin 155 A

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66392

1. OWNER RMP RESOURCES
MAILING ADDRESS 2778 SPOKANE CREEK RD.
EAST HELENA NONTANA, 59635

ADDRESS AT WELL LOCATION SOUTH OF EUREKA
GHM - 3
Subdivision Name: County: Eureka

2. LOCATION SW ¼ NE ¼ Sec 1 T 15N N/S R 52 E
PERMIT/WAIVER No. (Issued by Water Resources) Parcel No.
Latitude 39* 12' 8.13" N
Longitude 116* 03' 46.45" W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE CLAY		0'	10'	10'
SAND AND GRAVEL		10'	375'	365'

Date started: 10-Feb, 20 11
Date completed: 11-Feb, 20 11

RECEIVED 2011 MAR 11 AM 11:09 STATE ENGINEER'S OFFICE

9. WELL CONSTRUCTION
Depth Drilled 375' Feet Depth Cased 375' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12"	Inches	0'	Feet	15'	Feet
8"	Inches	15'	Feet	375'	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"		.188"	+2'	15'
2"		SCH. 40	+2'	375'

Perforations:
Type of perforation SCREEN
Size of perforation 0.020"
From 335' feet to 375' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement 0' to 15' ☒ Pumped ☐ Poured
☒ Cement Grout 0' to 312' ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 312' to 375' ☐ Pumped ☒ Poured
Type: BCJ 8 X 16
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 305' feet below land surface
Artesian Flow: NO G.P.M. 0 P.S.I.
Water Temperature: N/A °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hydro Resources-West, Inc. (Contractor)
Address 4975 W. Winnemucca Blvd. (Contractor)
Winnemucca NV, 89445
Nevada contractor's license number issued by the *State Contractor's Board* 56797
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* # 1713
Signed (By driller performing actual drilling on site or contractor)
Date 2-23-11

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

39.202320°N
116.062013°W
NAD 27 (T0)