

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 113311  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34392

1. OWNER FRIAS PHYLLIS M. MANAGEMENT ADDRESS AT WELL LOCATION W. BELL DR. EAST OF  
MAILING ADDRESS 5010 VALLEY VIEW TRAIL VALLEY VIEW DR. LAS VEGAS NV.  
LAS VEGAS NV. Subdivision Name: \_\_\_\_\_ County: CLARK

2. LOCATION NW 1/4 NW 1/4 Sec 29 T 21 N SR 61 E Latitude 36° 05' 55" 42 UTM E  NAD 27  
PERMIT/WAIVER No. 16229101035 Longitude 115° 11' 18" 02 N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Municipal/Industrial  Monitor  Stock  Air  Other HSA

5. WELL TYPE

LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
ASPHALT		0.0	0.25	0.25
SANDSTONE BASE		0.25	6.0	5.75
SILTY CLAY		1.0	7.0	6.0
CALICHE		7.0	12.0	5.0
SILTY CLAY		12.0	18.0	6.0
CALICHE		18.0	20.0	2.0
SILTY CLAY		20.0	28.0	8.0
CALICHE	YES	28.0	29.0	1.0
SILTY CLAY	YES	29.0	34.0	5.0
CALICHE	YES	34.0	39.5	5.5
FACILITY I.D. NO. <u>8-000204</u>				

WELL CONSTRUCTION				
Depth Drilled	Feet	Depth Cased	Feet	
<u>39.5</u>		<u>39.5</u>		
HOLE DIAMETER (BIT SIZE)				
	From	To		
<u>12</u>	Inches	<u>0.0</u>	Feet	<u>39.5</u> Feet
	Inches		Feet	Feet
	Inches		Feet	Feet
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>.5</u>		<u>0.065</u>	<u>0.0</u>	<u>39.5</u>

Perforations:  
Type of perforation MACHINE SLOT  
Size of perforation .020  
From 29.5 feet to 39.5 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No CLEAN FILL

<input type="checkbox"/> Neat Cement	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	<u>5.0</u> to <u>7.0</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	<u>0.0</u> to <u>1.0</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input checked="" type="checkbox"/> ≥30% Bentonite Grout	<u>7.0</u> to <u>21.5</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
Gravel Pack: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<u>29.5</u> to <u>39.5</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
Type:	<u>NO 3</u>		
Bentonite Chips: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<u>27.5</u> to <u>29.5</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
Type:	<u>3/8 SEAL</u>		

Date started: 10-4, 20 10  
Date completed: 10-4, 20 10

7. Water Level  
Static water level: 28.0 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

WELL TEST DATA		
TEST METHOD:	G.P.M.	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	Draw Down (Feet Below Static)	
<b>DNDR/DWR RECEIVED</b>		
<b>OCT 13 2010</b>		

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name EAGLE DRILLING Contractor  
Address 7150 PLACIO ST. LAS VEGAS NV  
89119  
Nevada contractor's license number issued by the State Contractor's Board 51266  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357  
Signed Neil Winkler  
By driller performing actual drilling on-site or contractor  
Date 10-8-2010