STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113357
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35247

1. OWNER Las Vegas Valley water District
MAILING ADDRESS 1001 South Valley VIEW BLVD
Las Vegas, NV 89153

ADDRESS AT WELL LOCATION 8551 W. Gowan
Las Vegas NV 89129 well #115
Subdivision Name: —
County: Clark

2. LOCATION NE ¼ SE ¼ Sec 08 T 20 N/S R 60 E
PERMIT/WAIVER No. 61493 (Issued by Water Resources) 138-08-701-013 (Parcel No.)

Latitude 36 13 33.34
Longitude 115 16 48.93
UTM E
N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brushed		0	1240	
bailed at Fill		1240	1260	

DCNR/DWR
RECEIVED
FEB 01 2011
LAS VEGAS OFFICE

Date started: Jan 21, 20 11
Date completed: Feb 1, 20 11

9. WELL CONSTRUCTION
Depth Drilled 1317 Feet Depth Cased 1260 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
48	Inches	0	Feet	70	Feet
18	Inches	70	Feet	1317	Feet
34	Inches	70	Feet	1280	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
36"		.375	0	70
24"		.375	+3	540
			660	700

Perforations:
Type of perforation: wire wrap screen
Size of perforation: .100

From 540	feet to 660	feet
From 700	feet to 1000	feet
From 1040	feet to 1240	feet
From	feet to	feet
From	feet to	feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☒ Cement Grout	to		☒ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to		☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 300 to 1280 ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Las Vegas Valley water District
Address (Contractor) 1001 So. Valley View BLVD
Las Vegas Nevada, 89153
Nevada contractor's license number issued by the State Contractor's Board —
Nevada driller's license number issued by the Division of Water Resources, the on-site driller LTD 2248
Signed (By driller performing actual drilling on-site or contractor)
Date Feb 1 2011

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY