

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 113364
Permit No. _____
Basin 076

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66180

1 OWNER PAUL KNOX ADDRESS AT WELL LOCATION 1510 SOUTH CLOVER LN
MAILING ADDRESS 1510 S. CLOVER LN FERNLEY, NV 89406
FERNLEY, NV 89406 Subdivision Name: _____ County: Lyon

2 LOCATION SW 1/4 SW 1/4 Sec 20 T 20N N/S R 25 E Latitude 39.58183°N UTM E NAD 27
PERMIT/WAIVER No. 020-381-05 Longitude 119.20791°W N NAD 83/WGS 84
Issued by Water Resources Parcel No.

3 TYPE OF WELL Domestic Irrigation Test Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? YES
If yes, what is replacement well NOI? 66179
Is there an existing well log? NO
If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION

Depth Drilled 72 Feet Depth Cased 72 Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.06	.188	+2	72

7 WELL PLUGGING PROCEDURE

Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:

Type of perforation	Size of perforation	From	feet to	To	feet
FACTORY SLOT	3 X 3/32			72	

Additional Perforations:

Type of perforator used:	From	feet to	feet	Number of perfs per linear foot
MILLS KNIFE	40	feet to	60	6

5 WATER LEVEL

Static water level 68 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COLD °F Quality BAD

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
0	feet to	72	NEAT CEMENT	<input checked="" type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments

PULLED OUT PUMP. PERFOR FROM 40 TO 60'
6 ROWS 12 INCHES APART

PLACED 2" TREEMING PIPE TO BOTTOM AND PUMPED
WITH NEAT CEMENT TO SURFACE.

Neat Cement Fluid Weight 94/4 lbs/gal
Bentonite Grout _____ % bentonite
Date Started 03/07/2011
Date Completed 03/07/2011

* See replacement log # 113303

RECEIVED
2011 MAR -9 AM 10:57
STATE ENGINEERS OFFICE

39.581917°N
119.206910°W

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. Contractor
Address # 20 KIT KAT DRIVE Contractor
CARSON CITY, NV 89706

Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905

Signed [Signature]
By driller performing actual drilling on site or contractor
Date 03/07/2011

MMH-F