

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY  
Log No. 113399  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34465

1 OWNER SCHOOL BOARD OF TRUSTEES ADDRESS AT WELL LOCATION 1700 GALLERIA DR.  
MAILING ADDRESS 2832 E. FLAMINGO RD. HENDERSON NV.  
LAS VEGAS NV. Subdivision Name: \_\_\_\_\_ County: CLARK

2 LOCATION MW 2 NW 1/4 Sec 33 T 21 N R 62 E Latitude 36° 04.5714 UTM E  NAD 27  
PERMIT/WAIVER No. 16133101602 Longitude 115° 03.3029 N  NAD 83/WGS 84

Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_

3 TYPE OF WELL  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

Is this well being plugged because a replacement well was drilled? NO  
If yes, what is replacement well NOI? \_\_\_\_\_

Is there an existing well log? NO  
If yes, what is NDWR well log #? \_\_\_\_\_

4 EXISTING WELL CONSTRUCTION  
Depth Drilled 25 Feet Depth Cased 25 Feet

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>SC440</u>	<u>0</u>	<u>25</u>

7 WELL PLUGGING PROCEDURE  
Was well cleaned out to total depth?  yes  no  
If well was not cleaned out to total depth, please explain why: \_\_\_\_\_

Was the well contaminated?  yes  no  
Was the casing pulled?  yes  no  
Was the casing over drilled?  yes  no

If casing was left in place, please show where additional perforations were made:  
Additional Perforations: \_\_\_\_\_

Type of perforator used:	From	feet to	feet	Number of perfs per linear foot
<u>None</u>				

Existing Perforations:  
Type of perforation MACHINE SCOT  
Size of perforation .020

From	feet to	feet	feet
<u>10</u>	<u>25</u>		

5 WATER LEVEL  
Static water level 11.7 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

8 WELL PLUGGING MATERIALS

Material Used				
From <u>0</u> feet to <u>1</u> feet	<u>CONCRETE</u>	<input type="checkbox"/> umped	<input checked="" type="checkbox"/> Poured	
From <u>1</u> feet to <u>25</u> feet	<u>CEMENT GROUT</u>	<input checked="" type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured	
From _____ feet to _____ feet		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
From _____ feet to _____ feet		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
From _____ feet to _____ feet		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
From _____ feet to _____ feet		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	

6 Additional Notes or Comments  
MW 2

Neat Cement Fluid Weight 94 lbs/gal 5.2  
Bentonite Grout \_\_\_\_\_ % bentonite  
Date Started 1-21-2011  
Date Completed 1-21-2011

**DCNR/DWR  
RECEIVED**

JAN 25 2011

**LAS VEGAS OFFICE**

9 DRILLER'S CERTIFICATION  
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name EAGLE DRILLING Contractor  
Address 7150 PLACIO ST. LAS VEGAS NV 89119 Contractor

Nevada contractor's license number 51266  
issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357

Signed Neil Winters  
By driller performing actual drilling on-site or contractor

Date 1-21-2011

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY