

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT**

**OFFICE USE ONLY**  
Log No. 113425  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

**PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 35516

1 OWNER USA Washington DC ADDRESS AT WELL LOCATION 450 Bruce Woodbury Drive  
MAILING ADDRESS \_\_\_\_\_ Laughlin, NV  
Subdivision Name: \_\_\_\_\_ County: Clark

2 LOCATION NW ¼ SE ¼ Sec 14 T 32S N/S R 66 E Latitude UTM E 26396766.33  NAD 27  
PERMIT/WAIVER No. R-1494 264-14-000-002 Longitude N 953855.32  NAD 83/WGS 84  
Issued by Water Resources Parcel No.

3 TYPE OF WELL  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
Is this well being plugged because a replacement well was drilled? No  
Is there an existing well log? Yes  
If yes, what is replacement well NOI? \_\_\_\_\_ If yes, what is NDWR well log #? 66838

4 EXISTING WELL CONSTRUCTION  
Depth Drilled 300 Feet Depth Cased 300 Feet  
EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

7 WELL PLUGGING PROCEDURE  
Was well cleaned out to total depth?  yes  no  
If well was not cleaned out to total depth, please explain why: No access; 7" casing; obtained waiver for no perfring.  
Was the well contaminated?  yes  no  
Was the casing pulled?  yes  no  
Was the casing over drilled?  yes  no

Existing Perforations:  
Type of perforation \_\_\_\_\_ Mill slot \_\_\_\_\_  
Size of perforation \_\_\_\_\_ 1/4"x2.5"  
From 260 feet to 300 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

If casing was left in place, please show where additional perforations were made:  
Additional Perforations:  
Type of perforator used: \_\_\_\_\_ None; waiver obtained  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet Number of perms per linear foot 15  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet Number of perms per linear foot \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet Number of perms per linear foot \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet Number of perms per linear foot \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet Number of perms per linear foot \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet Number of perms per linear foot \_\_\_\_\_

5 WATER LEVEL  
Static water level 112 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

8 WELL PLUGGING MATERIALS  
Material Used  
From 0 feet to 300 feet neat cement  Pumped  Poured  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  Pumped  Poured

6 Additional Notes or Comments  
Casing on log states 6 5/8"; however, when measured the casing is 7" I.D. waiver obtained because we don't have a perforator that is capable of perforating 7"  
Installed tremie pipe from top to bottom & pumped neat cement till full. (10 yards)

**DCNR/DWR  
RECEIVED  
JAN 27 2011  
LAS VEGAS OFFICE**

Neat Cement Fluid Weight \_\_\_\_\_ lbs/gal  
Bentonite Grout \_\_\_\_\_ % bentonite  
Date Started 12/15/2010  
Date Completed 12/21/2010

9 DRILLER'S CERTIFICATION  
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.  
Name ALLEN DRILLING INC. Contractor  
Address 4015 West Tompkins Ave. Contractor  
Las Vegas, NV 89103  
Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller MPDEW2343  
Signed [Signature] By driller performing actual drilling on site or contractor  
Date 12/29/2010