

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113449
Permit No. 80119
Basin 057

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66371

1. OWNER Rod Monk
MAILING ADDRESS HC61 Box 182
Battle Mountain, NV 89820

ADDRESS AT WELL LOCATION Antelope Valley
Battle Mountain, NV 89820
Subdivision Name: _____ County: Lander

2. LOCATION NE 1/4 SE 1/4 Sec 10 T 24N N/S R 40 E
PERMIT/WAIVER No. 80119
Issued by Water Resources Parcel No. _____

Latitude 39.96636 N UTM E NAD 27
Longitude -117.45333 W N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Sand/Gravel		0	50	50
Large Gravel		50	138	88
Brown Clay		138	187	49
Med Gravel		187	212	25
Brown Clay		212	233	21
Gravel	X	233	258	25
Brown Clay		258	271	13
Gravel w/streaks Clay	X	271	292	21
Clay		292	305	13
Clay w/Gravel	X	305	330	25
Brown Clay		330	356	26
Gray Clay		356	410	54
Hard Brown Clay		410	425	15
Gravel	X	425	436	11
Brown Clay		436	468	32
Gravel	X	468	485	17
Brown Clay w/Gravel		485	490	5
Gravel	X	490	505	15
Brown Clay		505	518	13
Large Gravel	X	518	570	52
Large Gravel	XX	570	610	40

9. WELL CONSTRUCTION				
Depth Drilled	610	Feet	Depth Cased	610
HOLE DIAMETER (BIT SIZE)				
	From	To		
	36	Inches	0	Feet 50
	24	Inches	50	Feet 610
		Inches		Feet
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42.09	.250	0	610
30	39.5	.109	0	50

Perforations:
Type of perforation Double Row
Size of perforation 0.25
From 212 feet to 610 feet
From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement to _____ Pumped Poured
 Cement Grout 50 to 0 Pumped Poured
 Concrete Grout to _____ Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 610 to 0 Pumped Poured
Type: 3/4" Well gravel

Bentonite Chips: Yes No to _____ Pumped Poured
Type: _____

7. Water Level
Static water level: 160 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: Cool °F
Quality: Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc.
Contractor
Address P.O. Box 1265
Contractor
Fallon, NV 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2285
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 3/15/2010

8. WELL TEST DATA		
TEST METHOD:		
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

USE ADDITIONAL SHEETS IF NECESSARY
39.966719° N
117.452388° W
NAD 27 (TA)

RECEIVED
2011 MAR 30 AM 11:13
STATE ENGINEERS OF NV