STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113536
Permit No.
Basin 137 B

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65794

1. OWNER Round Mountain Gold 2010-2
MAILING ADDRESS PO Box 480
Round Mtn., NV. 89405

ADDRESS AT WELL LOCATION Round Mtn. Mine
Round Mtn, NV.
Subdivision Name: County: Nye

2. LOCATION NW¼SW¼ Sec19T10N/ R44E
PERMIT/WAIVER NO. M/O - 1669
Issued by Water Resources Parcel. No.

Latitude 38.709592 UTM E 492215 ☒ NAD 27
Longitude 117.089537 N 4284347 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium Granite Dominate		0	75	75
Alluvium Tuff Dominate		75	195	120
Epiclastic Sandstone		195	265	70
Stibbins Hill Tuff		265	355	90
Rhyolite Welded Tuff		355	380	25

Installed a 2" pipe with transducers attached at 345, 280,200. Pumped cement grout through the 2" until it reached surface. Then inserted trimme pipe to 10' & pumped cement for a cement seal.

Hole is Abandoned

Date started: February 26, 20 11
Date completed: March 24, 20 11

9. WELL CONSTRUCTION

Depth Drilled 380 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9.875 Inches	0 Feet	20 Feet
6.50 Inches	20 Feet	380 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	3.65	.188	+1	360

Perforations:
Type of perforation None
Size of perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☒ Neat Cement	0 to 10	☒ Pumped	☐ Poured
☒ Cement Grout	10 to 380	☒ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to	☐ Pumped	☐ Poured
Gravel Pack: ☐ Yes ☒ No	to	☐ Pumped	☐ Poured
Type:			
Bentonite Chips: ☐ Yes ☒ No	to	☐ Pumped	☐ Poured
Type:			

7. Water Level
Static water level: 190 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5		.25

STATE ENGINEER'S OFFICE
2011 APR -1 PM 12:15
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (CONTRACTOR)
Address 2745 California Ave (CONTRACTOR)
SLC., UT. 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2376
Signed
By driller performing actual drilling on site or contractor
Date March 29, 2011