STATE OF NEVADA

DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 11359ϕ
Permit No.
Basin ϕ83

NOTICE OF INTENT NO. 66454

1. OWNER Miles Construction
MAILING ADDRESS 61 Industrial Parkway
Carson City, NV 89706

ADDRESS AT WELL LOCATION 100 Germany Ct
McCarren, NV 89434
Subdivision Name: USA Parkway County: Storey

2. LOCATION NE¼NW¼ Sec11T19N/ R22E
PERMIT/WAIVER NO. 005-061-31
Issued by Water Resources Parcel. No.

Latitude N39.53095 UTM E ☐ NAD 27
Longitude W119.48395 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other Geo Loops

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Multi colored Clays | | 0 | 130 | 130 |
| Tan Sandy Clays | | 130 | 219 | 89 |
| Brown Volcanics | | 219 | 303 | 84 |
| Well # 27 | | | | |
| Geothermal Heat Loop | | | | |
| Grouted from bottom to top | | | | |
| with Geo. grout & Sand Mix. | | | | |
| 1" Loops X2 per well. | | | | |

Date started: 3-8, 20 11
Date completed: 3-8, 20 11

7. Water Level
Static water level: feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: °F
Quality: not tested

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

9. WELL CONSTRUCTION
Depth Drilled 303 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 6 1/4 Inches | 0 Feet | 303 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | | | | |

Perforations:
Type of perforation
Size of perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout 0 to 303 ☒ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (CONTRACTOR)
Address 1600 Mt. Rose Hwy (CONTRACTOR)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23095
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed R. Bruce MacKay
By driller performing actual drilling on site or contractor
Date 3-21-11

STATE ENGINEER'S OFFICE
2011 APR 20 AM 11:05
RECEIVED

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com