

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 113603  
Permit No. \_\_\_\_\_  
Basin 103

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER JOHN PEGGY ELLENBURG ADDRESS AT WELL LOCATION NICKEL AVE. PAPAGO ST. SANDY VALLEY NV.  
MAILING ADDRESS P.O. Box 75704 LAS VEGAS NV 89193 Subdivision Name: \_\_\_\_\_ County: CLARK

2. LOCATION SE 1/4 Sec 26 T 24 N R 56 E Latitude 35° 49' 49.3 UTM E  NAD 27  
PERMIT/WAIVER No. 20026-801-031 Longitude 115° 39' 28.8 N  NAD 83/WGS 84  
Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  New Well  Replace  Recondition  Deepen  Other  
4. PROPOSED USE  Domestic  Irrigation  Test  Monitor  Municipal/Industrial  Stock  
5. WELL TYPE  Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	2	2
CLAY		2	4	2
CLAY		4	28	24
CALICHE		28	38	10
CLAY		38	56	18
CALICHE		56	61	5
CLAY		61	74	13
CALICHE	W.S	74	80	6
CLAY		80	91	11
CALICHE	W.S	91	103	12
CLAY		103	116	13
CALICHE	W.S	116	120	4

9. WELL CONSTRUCTION

Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>12 1/4</u>	<u>0</u>	<u>120</u>	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>4.33</u>	<u>PVC SCH 40 .316</u>	<u>0</u>	<u>120</u>

Perforations:  
Type of perforation SAW CUT  
Size of perforation 1/8" INCH BY 6" INCH 4 Row  
From 120 feet to 80 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout 50 FT to SCIFFRE  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 120 to 50  
Type: 3/8" INCH PEA GRAVEL  Pumped  Poured  
Bentonite Chips:  Yes  No to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_

Date started: 3-28, 20 11  
Date completed: 3-28, 20 11

7. Water Level  
Static water level: 65 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: COOL °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
G.P.M.			
Draw Down (Feet Below Static)			
Time (Hours)			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BUDGET DRILLING CO. Contractor  
Address P.O. Box 3505 Pahrump NV. Contractor  
89041  
Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board 40020  
Nevada driller's license number issued by the \_\_\_\_\_  
Division of Water Resources, the on-site driller 1573

Signed [Signature]  
By driller performing actual drilling on-site or contractor  
Date 3-28-2011

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY