

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 113607  
Permit No. \_\_\_\_\_  
Basin 163

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER JOHN & PEGGY ELLENBURG ADDRESS AT WELL LOCATION MALLITE AVE. + PAWNEE ST.  
MAILING ADDRESS P.O. Box 95704 LAS VEGAS NV. 89193 Subdivision Name: \_\_\_\_\_ County: CLARK  
NOTICE OF INTENT NO. 31422  
2. LOCATION NE 1/4 Sec 26 T 24 N R 56 E Latitude 35° 49' 512" UTM E \_\_\_\_\_  NAD 27  
PERMIT/WAIVER No. 200-26-801-027 Longitude 115° 39' 422" N \_\_\_\_\_  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  New Well  Replace  Recondition  Deepen  Other  
4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	2	2
CALICHE		2	4	2
CLAY		4	28	24
CALICHE		28	38	10
CLAY		38	56	18
CALICHE		56	61	5
CLAY		61	74	13
CALICHE	W.B	74	80	6
CLAY		80	91	11
CALICHE	W.B	91	103	12
CLAY		103	116	13
CALICHE	W.B	116	120	4

9. WELL CONSTRUCTION

Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>12 1/4</u>	<u>0</u>	<u>120</u>	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>4.33</u>	<u>PVC SCH 40 .316</u>	<u>0</u>	<u>120</u>

Perforations:

Type of perforation SAW CUT

Size of perforation 4 INCH BY 6 INCH 4 Row

From 120 feet to 80 feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured

Cement Grout to \_\_\_\_\_  Pumped  Poured

Concrete Grout 50' to SURFACE  Pumped  Poured

≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 120' to 50'  Pumped  Poured

Type: 3/8 INCH PEA GRAVEL

Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Type: \_\_\_\_\_

Date started: 3-24 20 11

Date completed: 3-24 20 11

7. Water Level

Static water level: 65 feet below land surface

Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water Temperature: COOL °F

Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BUDGET DRILLING CO. Contractor

Address P.O. Box 3505 Prater NV. Contractor

89041

Nevada contractor's license number 40020

issued by the State Contractor's Board

Nevada driller's license number issued by the 1573

Division of Water Resources, the on-site driller

Signed Annie Brown

By driller performing actual drilling on-site or contractor

Date 3-28-2011