STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113628
Permit No. 77062
Basin 104

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66181

1. OWNER GOLDEN SIERRA INVESTMENTS
MAILING ADDRESS 1665 SOUTH SUTRO TERRACE
CARSON CITY, NV 89706

ADDRESS AT WELL LOCATION 6100 GONI RD
CARSON CITY, NV 89706
Subdivision Name: County: Carson City

2. LOCATION SW ¼ SW ¼ Sec 28 T 16N N/S R 20 E
PERMIT/WAIVER No. 77062 (Issued by Water Resources) 080-011-58 Parcel No.
Latitude 39.21797*N Longitude 119.75001*W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. ✓ Commercial PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	4	4
COURSE DG SANDS		4	21	17
MEDIUM GRANITE		21	42	21
HARD GRANITE		42	110	68
SMALL DG FRACTURES	XX	110	136	26
HARD GRANITE		136	152	16
HARD FRACTURED GRANITE	XX	162	220	58

Date started: 29-Mar, 20 11
Date completed: 08-Apr, 20 11

9. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11 3/4	Inches	0	Feet	100	Feet
9 7/8	Inches	100	Feet	160	Feet
8 3/4	Inches	160	Feet	220	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	220

Perforations:
Type of perforation 3 x 3/32
Size of perforation FACTORY MILL SLOT
From 140 feet to 160 feet
From 180 feet to 200 feet
From 200 feet to 220 feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 100 ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 100 to 220 ☐ Pumped ☒ Poured
Type: PEAT GRAVEL
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 15 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35	110	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address 20 KIT KAT DRIVE (Contractor)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed Michael H Hack (By driller performing actual drilling on site or contractor)
Date 04/08/2011

STATE ENGINEER'S OFFICE
2011 APR 11 AM 9:16
RECEIVED

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

39.218060 °N
119.748995 °W
NAD 27 (T2)