STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113632
Permit No.
Basin 033A

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63547

1. OWNER Western Lithium Corp. - Bo Elgby
MAILING ADDRESS 3685 Lakeside Drive
Reno, NV 89509

ADDRESS AT WELL LOCATION Future Mine Site
sec 10, east of Orovada, NV ~ 20-23 miles
Subdivision Name: County: Humboldt

2. LOCATION SE ¼ SW ¼ Sec 10 T 44N N/S R 35 E
PERMIT/WAIVER No. M/O-1674
Issued by Water Resources Parcel No.

Latitude 41.70209
Longitude 118.03533
UTM E N
[X] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other SONIC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gray to dark silts and clays		0	40	40
Gray to dark hard shale/clays		40	300	260
Hard dark shale intermintent clays				
calcium lenses	x	300	500	200

Date started: 21-Feb , 20 11
Date completed: 2-Mar , 20 11

9. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 480 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.5	Inches	0	Feet	150	Feet
7.5	Inches	150	Feet	350	Feet
6.5	Inches	350	Feet	500	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.5		SCHD 80 PVC	+3	420
2.5		SCHD 80 PVC	470	480

Perforations:
Type of perforation SCHD 80 PVC SCREEN
Size of perforation .020
From 420 feet to 470 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 0 to 20 [X] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[X] ≥30% Bentonite Grout 20 to 400 [X] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 418 to 465 [ ] Pumped [X] Poured
Type: Monterey #3
Bentonite Chips: [X] Yes [ ] No 400 to 418 [ ] Pumped [X] Poured
Type: bottom hole 465' - 500' -- 3/8" - 3/4" Bentonite Pellets/Hole Plug

7. Water Level
Static water level: ~45 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pump	50	120	4

STATE ENGINEER'S OFFICE
2011 APR 11 AM 9:43
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (Contractor)
Address 3936 Railroad Avenue (Contractor)
Yuba City, CA 95991
Nevada contractor's license number issued by the *State Contractor's Board* 0021976
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2234
Signed (By driller performing actual drilling on site or contractor)
Date 4-7-11

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY