

**STATE OF NEVADA**  
**DIVISION OF WATER RESOURCES**  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 113634  
 Permit No. 071  
 Basin 071

**PRINT OR TYPE ONLY**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66943

1. OWNER **Alan Munk** ADDRESS AT WELL LOCATION **7045 Jackson Winnemucca, NV 89445**  
 MAILING ADDRESS **7045 Jackson - Winnemucca, NV** **Winnemucca, NV 89445**  
 Subdivision Name: \_\_\_\_\_ County: **Humboldt**

2. LOCATION NW 1/4 NE 1/4 Sec 13 T35N R37E Latitude N40°54.888 UTM E \_\_\_\_\_  NAD 27  
 PERMIT/WAIVER NO. N/A 013-541-05 Longitude W117°45.765 N \_\_\_\_\_  NAD 83/WGS 84  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock \_\_\_\_\_  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & rock		0	2	2
Rock & boulders		2	80	78
Clay w/rock		80	100	20
Gravel & Sand		100	115	15
Cobles & Clay		115	130	15
Cobles		130	170	40
Clay		170	180	10
Sand w/gravel	X	180	210	30
Clay		210	215	5
cobles & Gravel	X	215	230	15
clay		230	240	10
sand w/gravel		240	253	13

9. WELL CONSTRUCTION

Depth Drilled 253 Feet Depth Cased 253 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
11 Inches \_\_\_\_\_ Feet 253 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	13
6.625	4.06	.316	13	253

Perforations:  
 Type of perforation **Factory Cut Slots**  
 Size of perforation 050  
 From 213 feet to 253 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Gravel Pack:  Yes  No 50 to 253  Pumped  Poured  
 Type: \_\_\_\_\_  
 Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Type: \_\_\_\_\_

Date started: March 10, 20 11  
 Date completed: March 15, 20 11

7. Water Level  
 Static water level: 106 feet below land surface  
 Artesian Flow: N/A G.P.M. N/A P.S.I.  
 Water Temperature: Cool °F  
 Quality: Good

8. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>15</u>	<u>1.5</u>	<u>5</u>	
<u>30</u>	<u>3.0</u>		
<u>45</u>	<u>4.5</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Fred Anderson Drilling, Inc.**  
(CONTRACTOR)

Address **10760 S. Grass Valley Road**  
(CONTRACTOR)  
**Winnemucca, NV 89445**

Nevada contractor's license number issued by the State Contractor's Board 021467  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083

Signed Fred Anderson Drilling Inc  
 By driller performing actual drilling on site or contractor  
 Date April 11, 2011