

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 113644
 Permit No. 78982
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **35447**

1. OWNER **HARRIS RENTAL PROPERTIES LLC**
 MAILING ADDRESS **1401 S HWY 160 BLD A**
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION **5101 W BARTLETT LN**

2. LOCATION **NE** 1/4 **NE** 1/4 Sec. **22** T **20S**
 PERMIT NO. **78982** Issued by Water Resources
27-561-12 Parcel No.

N/S R **52** E **NYE** County
 Subdivision Name

3. WORK PERFORMED
 New Well
 Deepen
 Replace
 Abandon
 Recondition
 Other

4. PROPOSED USE
 Domestic
 Municipal/Industrial
 Irrigation
 Monitor
 Test
 Stock

5. WELL TYPE
 Cable
 Rotary
 RVC
 Air
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	20	20
CALICHIE		20	31	11
CLAY		31	65	34
CALICHIE		65	75	10
CLAY		75	95	20
CALICHIE	WB	95	100	5
CLAY		100	115	15
CALICHIE	WB	115	125	10
CLAY		125	140	15
CALICHIE	WB	140	153	13
CLAY		153	175	22
CALLICHIE	WB	175	180	5

N36°12'10.7"
 W116°06'15.1"

DCNR/DWR
 RECEIVED

APR 11 2011

LAS VEGAS OFFICE

Date started **4/1/2011**, 19
 Date completed **4/4/2011**, 19

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

8. WELL CONSTRUCTION

Depth Drilled **240** Feet Depth Cased **240** Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
12"	0	240		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	3.63	.280	0	240

Perforations:

Type perforation **SCREEN**
 Size perforation **.032**
 From **0** feet to **240** feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal **50**
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From **50** feet to **240** feet

9. WATER LEVEL

Static water level **65'** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.


Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.**
 Contractor

Address **1220 MANSE RD**
 Contractor

PAHRUMP, NV. 89048

Nevada contractor's license number issued by the State Contractor's Board **47333**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1426**

Signed 
 By driller performing actual drilling on-site or contractor

Date **4/7/2011**