

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. **113645**  
 Permit No. \_\_\_\_\_  
 Basin **162**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **35453**

1. OWNER **MELISSA HARDAN** ADDRESS AT WELL LOCATION **1450 E CASEY RD**  
 MAILING ADDRESS **3760 N POINT DR**  
**PAHRUMP, NV 89060**

2. LOCATION **NE** 1/4 **NW** 1/4 Sec. **11** T **21S** N/S R **53** E **NYE** County  
 PERMIT NO. \_\_\_\_\_ Parcel No. **44-471-15** Subdivision Name **NYE CREST ESTATES**

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  Cable  Rotary  RVC  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	30	30
CALICHIE		30	65	35
CLAY		65	75	10
CALICHIE	WB	75	95	20
CLAY		95	120	25
CALICHIE	WB	120	128	8
CLAY		128	160	32
CALICHIE	WB	160	165	5
CLAY		165	195	30
CALICHIE	WB	195	215	20
CLAY		215	235	20
CALICHIE	WB	235	260	25

N36°08'43.3"  
 W115°59'06.1"

**DCNR/DWR  
 RECEIVED**

APR 11 2011

**LAS VEGAS OFFICE**

8. WELL CONSTRUCTION  
 Depth Drilled **260** Feet Depth Cased **260** Feet

HOLE DIAMETER (BIT SIZE)

	From	To	Feet
12" Inches	0	260	Feet
Inches			Feet
Inches			Feet

CASING SCHEDULE


Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.280	0	260

Perforations:  
 Type perforation **SCREEN**  
 Size perforation **.032**

From	feet to	feet
From <b>200</b>	feet to <b>220</b>	feet
From <b>240</b>	feet to <b>260</b>	feet
From _____	feet to _____	feet
From _____	feet to _____	feet
From _____	feet to _____	feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal **50**  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From **50** feet to **260** feet

9. WATER LEVEL  
 Static water level **82** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor  
 Address **1220 MANSE RD** Contractor  
**1220 MANSE RD**  
 Nevada contractor's license number issued by the State Contractor's Board **47333**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1426**  
 Signed  by driller performing actual drilling on-site or contractor  
 Date **4/7/2011**

Date started **4/6/2011**, 19\_\_\_\_  
 Date completed **4/6/2011**, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
G.P.M. <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		