

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35198

1. OWNER Bonnie Wahl ADDRESS AT WELL LOCATION 1750 E Sage
 MAILING ADDRESS 1750 E Sage Amargosa Valley NV 89050
 2. LOCATION NE 1/4 NW 1/4 Sec. 35 T. 16 N. R. 49 E. 14 County Nye
 PERMIT NO. 20162 Issued by Water Resources Parcel No. 19-641-13 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary PVC
 Air Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------------------|--------------|------|-----|------------|
| Sand w/ gravel | | 0 | 130 | 130 |
| Large Gravel | 150 | 130 | 155 | 25 |
| Gravel w/ sand | | 155 | 180 | 25 |
| White Clay w/ sand | | 180 | 200 | 20 |
| Cemented Sand | | 200 | 215 | 15 |
| Brown Clay w/ sand | | 215 | 450 | 235 |
| Sand w/ brown clay film | | 450 | 530 | 80 |
| Sand + Gravel | | 530 | 585 | 55 |
| Sand w/ cemented gravel | | 585 | 600 | 15 |
| Bottom of hole 600 | | | | |
| N 36° 31' 50" | | | | |
| W 116° 25' 583" | | | | |

8. WELL CONSTRUCTION
 Depth Drilled 600 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)
 From 19 1/2 Inches To 0 Feet
 From 0 Feet To 600 Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>12</u> | <u>PVC</u> | | <u>0</u> | <u>600</u> |

Perforations:
 Type perforation Factory Machined
 Size perforation .832 x 3.875
 From 140 feet to 580 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 600 feet

9. WATER LEVEL
 Static water level 130 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |

Date started 4-13-2010, 19____
 Date completed 4-25-2010, 19____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge
 Name Cool Drilling Co
 Address HE 70 Box 544A
Amargosa Valley NV 89050
 Nevada contractor's license number 5376A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2140
 Signed Randy Wahl
 By driller performing actual drilling on site of contractor
 Date 4-11-11