

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 113652  
Permit No. 54276  
Basin 072

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66065

1. OWNER SUNRISE MINERALS ADDRESS AT WELL LOCATION DUN GLEN  
MAILING ADDRESS 7343 S. ALTON WAY # 100  
CENTENNIAL COLORADO, 80112 Subdivision Name: \_\_\_\_\_ County: Pershing

2. LOCATION SE 1/4 SE 1/4 Sec 17 T 33N N/S R 99 E Latitude 40° 43.640 N UTM E  NAD 27  
PERMIT/WAIVER No. 54276 Parcel No. 36 Longitude 117° 57.059 W N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY WITH GRAVELS		417'	755'	338'
CLAY		755'	790'	35'
CLAY WITH GRAVELS		790'	980'	190'
40.727428°N NAD 27 D.D. 117.950014°W				
201 APR 18 AM 11:25 STATE ENGINEER OF THE				
deepens well log # 34266				

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
HOLE DIAMETER (BIT SIZE)			
8"	Inches	From 417'	To 980' Feet
	Inches		Feet
	Inches		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"		.188"	400'	980'

Perforations:

Type of perforation	Size of perforation
MILL SLOT	0.090" X 3"
From 485'	feet to 980' feet
From	feet to feet
From	feet to feet
From	feet to feet

Annular Seal:  Yes  No

Neat Cement to  Pumped  Poured  
 Cement Grout to  Pumped  Poured  
 Concrete Grout to  Pumped  Poured  
 ≥30% Bentonite Grout to  Pumped  Poured

Gravel Pack:  Yes  No to  Pumped  Poured  
 Type: \_\_\_\_\_  
 Bentonite Chips:  Yes  No to  Pumped  Poured  
 Type: \_\_\_\_\_

Date started: 24-Mar, 20 11  
Date completed: 3-Apr, 20 11

7. Water Level  
Static water level: 234' feet below land surface  
Artesian Flow: NO G.P.M. 0 P.S.I.  
Water Temperature: COOL °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
CONSTANT	24	219'	6 HOURS

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hydro Resources-West, Inc. Contractor  
 Address 4975 W. Winnemucca Blvd. Contractor  
Winnemucca NV, 89445  
 Nevada contractor's license number 56797  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the # 1713  
 Division of Water Resources, the on-site driller  
 Signed Michelle Stroth  
 Date 4/14/11 Contractor Representative

MMH (P)