STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113672
Permit No.
Basin 072

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65936

1. OWNER Travel Center of America
MAILING ADDRESS 24601 Centre Ridge Rd ste 200
West Lake Ohio 44145

ADDRESS AT WELL LOCATION Travel Centers Truck Stop
6000 E Frontage Rd Millcity NV 89418
Subdivision Name: County: Pershing

2. LOCATION NW ¼ NW ¼ Sec 33 T 33 N/S R 35 E
PERMIT/WAIVER No. 5-000016 (Issued by Water Resources) 008-130-01 (Parcel No.)
Latitude N 40.69373° Longitude W 118.05686°
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand silt Gravel	No	0	25	25
Sand silt	No	25	30	5
Sand silt Gravel	No	30	40	10
Sand silt	No	40	45	5
Sand silt Gravel	Yes	45	75	30

MW-6

RECEIVED 2011 APR 25 AM 11:00 STATE ENGINEER

Date started: 3/15/11 , 20 11
Date completed: 3/16/11 , 20 11

7. Water Level
Static water level: 58 feet below land surface
Artesian Flow: no G.P.M. P.S.I.
Water Temperature: < 85 °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 75 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	75	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Schedule 40	0	45

Perforations:
Type of perforation Factory Slot
Size of perforation .020
From 45 feet to 75 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 33 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 43 to 75 ☐ Pumped ☒ Poured
Type: 10/20 Silica Sand
Bentonite Chips: ☒ Yes ☐ No 33 to 43 ☐ Pumped ☒ Poured
Type: 3/8 Bentonite Chips

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz-Tech Deilling Inc (Contractor)
Address Po Box 940 (Contractor)
meridian, Id 83680
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2412-M-LTD
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 4/8/11

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

40.693825°N
118.055887°W
NAD 27 TA

(NSPO 3-08) (O) 627