

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 113674  
Permit No. φ 72  
Basin φ 72

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65936

1. OWNER Travel Center of America ADDRESS AT WELL LOCATION Travel Centers Truck Stop  
MAILING ADDRESS 24601 Center Ridge Rd Ste 200 Westlake, Ohio 44145 6000 E Frontage RD, Mill City NV 89418  
Subdivision Name: \_\_\_\_\_ County: Perching

2. LOCATION NW 1/4 NW 1/4 Sec 33 T 33 R 35 E Latitude N40.69387° UTM E \_\_\_\_\_  NAD 27  
PERMIT/WAIVER No. 5-00016 008-130-01 Longitude W118.05683 N \_\_\_\_\_  NAD 83/WGS 84  
Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  New Well  Replace  Recondition  Deepen  Other

4. PROPOSED USE  Domestic  Irrigation  Test  Stock  Monitor  Municipal/Industrial

5. WELL TYPE  Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>sand silt Gravel</u>	<u>NO</u>	<u>0</u>	<u>20</u>	<u>20</u>
<u>sand silt cemented</u>	<u>NO</u>	<u>20</u>	<u>25</u>	<u>5</u>
<u>sand silt Gravel</u>	<u>NO</u>	<u>25</u>	<u>30</u>	<u>5</u>
<u>sand silt cemented</u>	<u>NO</u>	<u>30</u>	<u>45</u>	<u>15</u>
<u>sand silt Gravel</u>	<u>NO</u>	<u>45</u>	<u>50</u>	<u>5</u>
<u>sand silt</u>	<u>YES</u>	<u>50</u>	<u>70</u>	<u>20</u>
<u>sand silt Gravel</u>	<u>YES</u>	<u>70</u>	<u>75</u>	<u>5</u>

9. WELL CONSTRUCTION

Depth Drilled 75 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)

	From	To	Feet
<u>8"</u>	<u>0</u>	<u>75</u>	<u>75</u>
_____	_____	_____	_____
_____	_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	_____	<u>schedule 40</u>	<u>0</u>	<u>75</u>

Perforations:

Type of perforation Factory slot

Size of perforation .020

From 45 feet to 75 feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement 0 to 33  Pumped  Poured

Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 43 to 75  Pumped  Poured

Type: 10/20 silica sand

Bentonite Chips:  Yes  No 33 to 43  Pumped  Poured

Type: 39 Bentonite chips

7. Water Level

Static water level: 59' feet below land surface

Artesian Flow: no G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_

Water Temperature: 64.5 °F

Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Haz-Tech Drilling Inc Contractor

Address P.O. Box 940 Contractor

Meridian, Id 83680

Nevada contractor's license number \_\_\_\_\_

issued by the State Contractor's Board 0038018

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2412-M-LTD

Signed [Signature]

By driller performing actual drilling on-site or contractor

Date 4/8/11

40.693965° N  
118.055857° W  
NAD 27 (TD)