

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 03114

1. OWNER Stantec (for RTC) ADDRESS AT WELL LOCATION SE Connector Sparks, NV
 MAILING ADDRESS 6980 Sierra Center Plany #100 Reno NV 89511
 2. LOCATION NW 1/4 NE 1/4 Sec. 22 T. 19 R. 20 E. Washoe County
 PERMIT NO. M10 1088 Issued by Water Resources Parcel No. 021-030-00 Subdivision Name N39.50320 W119.72228

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other auger

6. LITHOLOGIC LOG Sec-8

Material	Water Strata	From	To	Thickness
<u>clayey silt w/ sand (dk brown - dk grey) brown</u>		<u>8.22</u>	<u>0</u>	<u>18</u>

RECEIVED
 2011 APR 25 PM 1:22
 STATE ENGINEER OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 18 Feet Depth Cased 18 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 18 Feet
 Inches Feet Feet Feet
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>18</u>

Perforations:
 Type perforation Sac
 Size perforation 020
 From 2.5 feet to 18 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 2.5 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 2.5 feet to 18 feet

9. WATER LEVEL
 Static water level 8.22 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Cold °F Quality N/A

Date started 3/30, 2011
 Date completed 3/30, 2011

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
	<u>39.503 285</u>	<u>119.72 1259</u>	<u>N/A 27 TA</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Androsen Drilling
 Address 1635 Belford rd. Reno NV 89509
 Nevada contractor's license number issued by the State Contractor's Board 34525
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed Andy Androsen
 Date 4/20/11