STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113690
Permit No. 78646
Basin 102

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66186

1. OWNER ANDRE AND VICKI BEAUPRE
MAILING ADDRESS 775 SUTRO SPRINGS RD
DAYTON, NV 89403

ADDRESS AT WELL LOCATION NOT GIVEN YET
ADREAN VALLY, NV 89429
Subdivision Name: County: Lyon

2. LOCATION SE ¼ SW ¼ Sec 34 T 16N N/S R 24 E
PERMIT/WAIVER No. 015-711-05
Issued by Water Resources Parcel No.

Latitude 39.20223*N
Longitude 119.26879*N
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
03 OVERBURDEN		0	3	3
DG SANDS		3	20	17
GRAVELS SMALL SANDS		20	75	55
BROWN CLAY		75	80	5
SMALL GRAVELS DG SANDS				
SOFT SPOTS	X	80	130	50
BROWN CLAY		135	140	5
DG SANDS AND GRAVELS	XX	140	160	20

Date started: 20-Apr, 20 11
Date completed: 23-Apr, 20 11

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
~~13.03~~	~~.188~~	.188	+2	160
6 5/8	13.03			

Perforations:
Type of perforation FACTORY MILL SLOT
Size of perforation 3X 3/32
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 100 ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 100 to 160 ☐ Pumped ☒ Poured
Type: PEAT GRAVEL
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 25 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	65	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address # 20 KIT KAT DRIVE (Contractor)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed Michael Hack (By driller performing actual drilling on-site or contractor)
Date 04/23/2011

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

39.202312°N
119.267800°W
NAD 27 (T8)