STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113714
Permit No.
Basin 137B

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65802

1. OWNER Round Mountain Gold Corp DV-11-34
MAILING ADDRESS P.O BOX 480
Round Mtn. NV. 89405

ADDRESS AT WELL LOCATION Round Mountain Mine
Subdivision Name:
County: Nye

2. LOCATION SW¼NE¼ Sec30T10N/ R44E
PERMIT/WAIVER NO. M/O-1667
Issued by Water Resources
Parcel. No.

Latitude
Longitude

UTM E 492934 ☒ NAD 27
N 4282983 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
White/Grey Rock		0	100	100
White Rock		100	200	100
White/ Red Rock		200	240	40
White Rock		240	400	160
Grey Rock		400	500	100
Grey/Black Rock		500	600	100

Plugged by well log #116789

Date started: April 18, 20 11
Date completed: April 19, 20 11

9. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9.875 Inches	0 Feet	20 Feet
6.500 Inches	20 Feet	600 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	.98	.218	+1	600

Perforations:
Type of perforation Slotted
Size of perforation 1/4
From 100 feet to 600 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 100 to 600 ☐ Pumped ☒ Poured
Type: 1/4 x 1/8 SR
Bentonite Chips: ☒ Yes ☐ No 50 to 100 ☐ Pumped ☒ Poured
Type: 3/8 Hole Plug

7. Water Level
Static water level: N/A feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (CONTRACTOR)
Address 2745 California Ave (CONTRACTOR)
Salt Lake City, UT. 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 23390
Signed
By driller performing actual drilling on site or contractor
Date April 28, 2011

RECEIVED MAY 4 2011 STATE ENGINEER'S OFFICE

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk • (214) 340-9429 • FormsOnADisk.com

38.697306°N
117.081254°W NAD 27 (T)